A Comparison of Contemporary Electrical Distribution Equipment Standards

San Francisco IEEE Industry Applications Society May 26, 2009

What are "Standards"?

- Clearly defined performance characteristics
- Based on tested performance under expected worse case parameters
- Generally based on third party certification of tested performance
- Vendor or supplier independent

Provide the basis for objective based comparison of performance under expected conditions of operation

An Example



Contemporary Standard -- Octane

- RON = Research Octane Number (fuel based); MON = Motor Octane Number (load/timing based)
- PON = Pump Octane Number; PON = (RON + MON)/2
- Uniform among suppliers to allow selection of proper grade by users,

BUT,

- Does not prevent misapplication due to perception
- Does not insure all suppliers offer the same product/features
- Can be revenue/margin tool for vendor

High Octane - Premium Unleaded



Low Octane - Regular Unleaded



What Rating is Required?



Electrical Distribution Equipment

- Divides Larger Amounts of Power into Smaller "Chunks"
- Can contain control and metering/monitoring devices
- Contains protective feeder devices whose prime role is to protect feeders
- Low Voltage Application include Panelboards, Switchboards, Switchgear

Watt's Engine





E = IR

W = EI

James Watt 1736 -- 1819

746 Watts = 1 Horsepower 600 Amps @ 480V 3ph = 665 HP 10,000 Amps @ 120V 1ph = 1600 HP

Office Building



65,000 AIC @ 480V = 72,300 HP

Medium Voltage



40,000 AIC @ 13,800V = 1,300,000 HP

Fault Testing



Fault Testing



Interaction in Equipment



- Opening Contacts Create Arcing
- Arcing Creates Resistance
- Resistance Reduces Current Flow
- Reduced Current Flow Can Affect Opening Speed
- Reduced Opening Speed Will Affect Energy Flow

Dynamic Interactions

- Individual devices react to what they see
 - Circuit Breakers react to over current or short circuit conditions
 - Relays operate based on on conditions sensed
- Individual devices react to the reaction of other devices
 - A circuit breaker that is tripping (opening under load) will affect the current and voltage seen by other devices

Selectivity Can Be Impacted



• Depending on fault level, more than one device can open on a downstream fault

- Loads without faults can be affected or interrupted
- Entire systems can be shutdown by downstream faults
- May be part of design for series ratings

Possible Conditions of Operation

- High Energy Levels Need to insure proper operation at possible fault levels
- Dynamic Interaction Need to understand possible device interactions under fault conditions
- Selectivity Need to insure required selectivity under all potential fault conditions

BUT,

• Cost – Need to meet all performance requirements within budgetary constraints

LV Equipment Standards

- NEMA Switchboards PB-2/Switchgear SG-5
 - No longer writing standards; still responsible for certain breaker testing standards
- ANSI Switchgear C37.20
 - Publishes standards; no longer creates standards for electrical equipment
- IEEE Switchgear C 37.20
 - Develops standards for equipment/breakers
- UL Switchboards UL 891/Switchgear UL 1558
 - Both develops standards and serves as third party certifier of devices and systems

Switchboards or Switchgear

- Terms often used interchangeably by many in industry; Switchgear is generic term
- Per NEC Article 100, difference is far from contemporary.
- Objective differences now defined by UL/ANSI standards for equipment

BUT,

- Many design elements can overlap
- Common components possible

Devices, not Equipment are Key

- OCPD (Over Current Protective Devices) determine the operational characteristics of the equipment
- Application of OCPDs determines equipment type (equipment standards)
- As in most cases, compromises may be required to obtain optimal solution for particular situation

Circuit Breakers

LV Power Circuit Breakers

- Since 1985, LV Power Circuit Breakers listed under UL 1066
- Formerly under ANSI C37.13 and C37.50 (not UL)
- Classic design was iron frame; most now enclosed with nonmetallic materials
- Allow for maintenance of internal parts for long service life
- Higher performance and higher cost

Molded Case Circuit Breakers

- Listed under UL 489
- Includes "insulated" case circuit breakers
- Classic design was toggle type thermosetting or thermoplastic sealed case
- Sealed case prevents normal maintenance
- Tend to be lower cost than Power Circuit Breakers
- High AIC ratings possible

LV Power Breakers Evolution



Key Differences UL 489 vs. UL 1066

- Higher endurance testing for UL 1066 at all ratings (e.g., 800A 500 cycles UL 489; 800 cycles UL 1066 at FLA)
- Short time withstand test required for UL 1066 rating – maintain high level current for 0.5 seconds
- Single pole testing for UL 1066
- Different power factor requirements for testing
- Different heat rise requirements for testing

Switchboards or Switchgear -- UL

- Switchgear listed to UL 1558 since 1982
- Based on ANSI C37 standards
- Uses UL 1066 listed breakers
- Generally requires rear access for load and incoming connections
- "Compartmentalized" Construction with breaker compartment for each device
- Tested to short circuit rating for 4 cycles (.067 seconds)
- Tested to short time rating for 30 cycles (0.5 seconds)
- Heat Rise tested Bussing

- Switchboards listed to UL 891
- Uses UL 891 or UL 1066 listed
 breakers
- Can be front connected without rear access requirements
- Devices can be individually (vertically) or group (panel/horizontally) mounted
- Tested to short circuit rating of 3 cycles (.05 seconds) or to instantaneous trip of tested OCPD or braced to UL configuration standards
- Heat Rise Tested or Density Rated

Why Require UL1558/UL1066?

- Allows use of tested assemblies/devices without instantaneous trips for selectivity
 - May be required to allow for slower relays for differential protection
 - Will insure selectivity to limit of short time ratings (to instantaneous over ride limits)
- May provide features/designs not available in UL 891 products from some manufacturers
 - Insulated and/or isolated bussing
 - Protected wire ways for LV controls

Selectivity Can Be Restored



• By eliminating instantaneous on one or more levels, selectivity can be maintained

• Arc Flash protection can be enhanced by differential relaying or arc flash relays

•Requires UL 1558 equipment for LV applications wherever instantaneous protections is eliminated

Why Not?

- Unless features/characteristics are not available in UL 891, UL 1558 equipment tends to be more costly.
 - GE study showed 1.6 to 2.0 unit cost difference between equivalent UL 891 and UL 1558 assemblies
- Rear access may not be available
 - Foot prints may be similar in square footage; required space may vary due to rear clearance requirements
- UL 1066 devices can be used in UL 891 equipment
 - Some manufacturers offer equivalent UL 489 devices; others only offer UL 1066 devices
 - Can NOT "turn off" instantaneous trip and maintain UL
- Unusual busing configurations may not be available in UL 1558 equipment
 - Only tested configurations are possible in UL 1558; UL 891 can use approved bracing configurations to create "custom" configurations.

Diesel - The European Standard



Standards Vary





IEC Standards

- IEC 60439 -1 (Low Voltage Switchgear and Controlgear Assemblies)
 - Can be either TTA (Type Tested Assembly) or PTTA (Partially Type Tested Assembly)
 - PTTA requires calculations for those parts not type tested
 - Includes both Switchgear and Switchboard equivalents
- IEC 60947 (Low Voltage Power Circuit Breakers)
- IEC 298 (Medium Voltage Switchgear and Controlgear Assemblies
 - Includes both metal enclosed and metal clad equivalents

Significant Configuration Differences



Typical MV Configuration



IEC Adaptations

- Many components originally designed for IEC markets successfully adapted/modified to meet UL standards
- IEC electrical equipment products generally not yet adapted to UL standards although efforts are ongoing
- IEC MV equipment successfully adapted to CSA standards (required some IEEE/ANSI testing)
- Increased demand for IEC equipment by users
- Often supplied as part of other equipment for food processing or similar applications

Final Notes

- Knowledge of standards and implications will drive most cost effective solutions for varied applications one size does NOT fit all
- Differentiating between what is required by standards and what is desired for the particular application (particularly on features) will allow more choices as to suppliers
- Final acceptance of equipment is dependent on local authorities (AHJ). Independent certification of standards will usually insure acceptance.