

# Distribution System State Estimations: Practical challenges, limitation of current tools and way forward

## DSA WG Meeting minutes

Monday, July 28, 2014

Room: Azalea 3 at Gaylord Hotel and Convention Center, National Harbor, MD

Start: 3:00 PM

3:00 PM Start of the meeting with Bikash showing the agenda

3:05 Self introduction of the attendees and signing in

3:15 Bikash started the discussion by highlighting the questions asked in last WG meeting

3:16 Bikash invited the comments from attendees on the "Existing DSSE technologies and their limitations"

- Kevin highlighted the issue that the utilities pull only real power information from the meters due to economic reasons. The reactive power information which is important for SE is not available for estimation.
- Also the models good representatives of the system behaviour which compromises the accuracy
- Tom McDermot from university of Pittsburgh mentioned that in dynamic estimation, the accuracy is a challenge as the measurements are not recorded in real time, instead they are average value of measurement of data taken over period of 15 minutes.
- There was a discussion about the use of PMUs in DSSE. It was concluded that a focused case to bring PMUs is not clear.
- Ahmad Majeed from university of Stuttgart highlighted the scenario of metering in Germany. He pointed out that measurements are available every 3 seconds, but measurement mean values are collected every 15 minutes due to legal requirements. Real time communication with smart meters is not allowed due to privacy concerns.
- Mingguo Hong from Case Western Reserve University pointed out that weights of measurements are accurate for regular behaviour, but bad for customers with irregular behaviour.

3:36 Bikash initiated a discussion on the topic "How fast the estimator should run?"

- It was pointed by the attendees that this depends on application. For example voltage regulation require estimator to run within half an hour time frame.
- Kevin mentioned the topology processing time prior to run of estimator.
- Yinhua Guo mentioned that topology processing is very limited in distribution system
- Bikash pointed out that tap position change causes a challenge in topology processing and tap position can be considered as a measurement.

3:46 Finally, Bikash invited the discussion on target DSSE applications. The following applications came up during the discussion:

- Voltage Var optimization, feeder reconfiguration, DG/DER based ancillary services, , frequency response, demand response

3:56: Bikash made a proposal for a Panel session for next year General Meeting.

4:00: Adjourn

List of Attendees:

<b>Name</b>	<b>Organization</b>	<b>Email</b>
Bikash Pal	Imperial College London	b.pal@imperial.ac.uk
Ravindra Singh	ABB Inc.	ravindra.singh@us.abb.com
Roger Dugan	EPRI	r.dugan@ieee.org
Bo Yang	Siemens	YANG_BO@siemens.com
Kevin Schneider	PNNL	kevin.schneider@pnnl.gov
Habiballah Rahimi Eichi	NCSU	hrahimi@ncsu.edu
Djalma Falcao	Federal University of Rio de Janeiro	falcao@nacod.ufrj.br
Kaigui Xie	Chongqing University	kaiguixie@uip.163.com
Visvakumar Aravinthan	Wichtia State	aravinth@ieee.org
Pengwei Du	ERCOT	pengwei.du@ercot.com
Ahmad Abdel-Majeed	University of Stuttgart	ahmed.abdel-Majeed@ieh.uni-stuttgart.de
Yinhua Guo	Hydro One	Yinhua.Guo@hydroone.com
Kehinde Awodele	University of Capetown	kehinde.awodele@uct.ac.za
Razon Alvin	DOE/SRA	alvin.razon@ee.doe.gov
Greg Shirek	Milsoft	greg.shirek@milsoft.com
Mingguo Hong	Case Western Reserve University	mxh543@case.edu
Aniss Fradi	Schneider Electric	aniss.fradi@schneider_electric.com
Tom McDermott	University of Pittsburgh	t.mcdermott@ieee.org
Hossein Darrish	Southern Illinois University	hdarris@siue.edu
Ankur Majumdar	Imperial College London	ankur.majumdar@imperial.ac.uk
Fernanda Trindade	University of Campinas	fernanda@ieee.org
Eduardo Asada	University of Sao Paulo	easada@usp.br
Vahraz Zamani	NCSU	vzamani@ncsu.edu
Mohammad C. Bozchalui	NEC Labs	m.chehreghani@ieee.org
Cavin Zhang		czhang@nexant.com