








## Transformerless UPS Designs
















































- PDU energy savings all relate to the efficiency of the transformer used in the design
- The normal dry-type transformer used in PDU's has been of "standard" high efficiency type
- All distribution transformers are now required to be the more energy efficient TP-1 type since January 2007
- Higher initial cost of TP-1 is quickly offset by energy savings


**FACI** 

**VIEEE** Central Tennessee Section





Three-phase kVA	Standard efficiency level (%)	TP-1-2002 efficiency level (%)		
30	96.5	97.5		
45	96.6	97.7		
75	96.7	98.0		
112.5	96.9	98.2		
150	97.1	98.3		
225	97.3	98.5		
300	97.4	98.6		








	Regular Transformer	Energy Efficient Transformer	Difference
Additional Costs for TP1		Transionner	\$4,250
Efficiency	97.30%	98.60%	1.30%
Annual cost of losses *	\$2,202	\$1,142	\$1,060
Simple payback (yrs.)			4.01
Lifetime cost of losses *	\$30,310	\$15,720	
Present value of savings			\$14,590
Overall Savings for 10	00 PDUs	\$1,459	,000
• Above is an ac		_	




























































































omparison of system designs, Tier II Da	ta Contor at	5kW per rad	<b>.</b>
		-	
oom Size	24'x48'		
quare Ft	1152		
otal equipment racks	42		Improvement using
	Unique	Legacy	Improvement using new technology
PS & Battery only racks	3	6	50%
ower distribution racks	0 + (18 x 3U)	3 x 42U	
otal U for distribution	54U	126U	57%
otal usable "U" space	1584	1386	198U (4.7 racks) 15%
otal sq Ft used for power	21	36	41%
otal usable kW @ 5kW per rack	180 kW	165kW	9%
/atts per Sq Ft	156	143	9%
ns of cooling for UPS systems	1.4	4.0	65%
mber of 3 phase cables from power distribution to		-	
ks	18	33	45%
timated Cable Used	180 ft	330 ft	45%
ergy usage per year (165kW @ \$.10 kWhr)	\$ 148,876	\$ 156,826	5%
tal energy savings in 5 years	\$39.	748	
tal cooling energy savings 5 years (70% ratio)	\$27.824		
tal savings during 5 years of operation	\$67.572		

