


Music City Power Quality
IEEE Control Tennessee Section
2015



Mike Mattingly
August 4th, 2015



Make the most of
your energySM



Presenter

Mike Mattingly, CEM

Midwest Regional Team Leader – Sr Drive Specialist

- Mike.Mattingly@us.schneider-electric.com
- 317-292-4537 cell



- 25 years in the Electrical Industry
 - Gas turbine Systems Electrical Engineer (US Navy)
 - Industrial Electrician – 5 years
 - Product Application Engineer – 15 years
- Sr Drive Specialist with Schneider Electric – 9 years
 - Midwest Regional Team Leader – Michigan, Tennessee, Kentucky, Indiana, Ohio, Chicago, Wisconsin,
- Certified Energy Manager – Association of Energy Engineers

Schneider Electric U.S.

Schneider Electric

The Global Specialist in Energy Management

18000


people across the country

240

facilities across the country

- 40 Manufacturing facilities
- 6 Distribution centers
- 6 R&D centers
- Business, sales & services

Sales



Market Leading Brands



Today's Discussion

- **Variable Frequency Drives – Basic Technology**
- **Application Considerations**
- **VFD Control scheme discussion**
- **Q & A**



Variable Frequency Drives common names are:

- Variable Frequency Drives - VFD
- Adjustable Frequency Drives – AFD

- Variable Speed Controllers - VSC
- Adjustable Speed Controllers – ASC
- Variable Speed Drives - VSD
- Adjustable Speed Drives – ASD
- AC Drives
- Inverter Drives




Soft Start vs VFD



Means of Controlling Flow & Pressure

- Typical Output Controls include:
 - Throttle valves
 - Inlet guide vanes
 - Outlet dampers
 - Mechanical speed changers
 - Eddy Current Clutch
 - Belt Drive
 - Two-speed Motor
- Motor runs at full speed
 - No energy savings

Why replace a motor starter with a VFD?



Why use VFD's?

- Provide substantial energy savings - #1
- Built in Soft Start – reduces mechanical shock
- Reduces downtime & improves system reliability
- Reduces maintenance & operational cost
- Improves system efficiency
- Precise process speed & torque control
- Provides application flexibility

Energy Savings \$\$\$

Studies show 60% of the energy used in the USA is used by motors.

Many of these motors are on fans & pumps (70% +)

Affinity Laws govern savings


Variable torque loads = fans, blowers & centrifugal pumps



Larger motors eat your lunch money!




Feed Me!



VFD Basics – Energy Savings

Percent
Flow, HP, Pressure



- A** = Flow as a function of motor speed
- B** = Pressure as a function of motor speed
- C** = Horsepower as a function of motor speed

Motor Speed

A motor running at 80% of full speed requires half of the electricity of a motor running at full speed.

Energy Savings Analysis

Where's the money going?



Typical drive energy payback period

- ❑ 1 – 3 year on just energy saved (demo software)

Payback based upon

- ❑ Energy cost, hours & speed of operation
- ❑ On-line software tool

VFD Basics – Energy Savings

- Situation – Aeration basin

- A 500hp centrifugal blower
- Supply air 10 hours/day for 250 days
- Cost at full speed would be:

$$500 \text{ hp} \times 0.746 \text{ kW/hp} \times 2500 \text{ hours} \times \$0.08 / \text{kWhr} = \$74,600.00$$

- Assuming the blower does not have to run at full speed all the time

- 25% of time at 100% speed = 625 hours
- 50% of time at 80% speed = 1250 hours
- 25% of time at 60% speed = 625 hours

- Cost running with a Schneider Electric AC Drive:

- $500 \times (1.0)^3 \times 0.746 \times 625 \times \$0.08 = \$18,650.00$
- $500 \times (0.8)^3 \times 0.746 \times 1250 \times \$0.08 = \$19,097.60$
- $500 \times (0.6)^3 \times 0.746 \times 625 \times \$0.08 = \$ 4,028.40$

- Annual savings (\$74,600.00 - \$41,776.00) is \$32,824.00

VFD – What does it give you?

- Controls speed of an AC motor.
 - Controls inrush current of an AC motor.
 - Generates full torque of the motor at very low speeds.
 - Protects the motor and wiring from overload currents.
 - Provides built in power factor correction.
-
- Allows simple connection to a communication network.
 - Allows automatic set point control throughout the entire speed range.
 - Provides a simple means to continuously monitor & diagnose.

VFD Driven Loads

- **Constant Torque – 150% over current for 1 minute**
 - Positive displacement pumps
 - Extruders
 - Centrifuges
 - Mixers
 - Agitators
 - Conveyors
 - Cranes
 - Paper machines
- **Variable Torque – 110% over current for 1 minute**
 - Centrifugal pumps
 - Fans
 - Blowers


Applications




- **Booster Pumps**
 - Energy savings, soft start
- **Exhaust Fans**
 - Energy savings
- **Blower Compressors**
 - Flow control, energy savings

Typical Building Applications

Cooling Tower Fans




VFD Basics




Voltz/Hz Ratio


- When current is applied to an induction motor it generates magnetic flux in its rotating field and torque is produced.
- This magnetic flux must remain constant in order to produce full-load torque, which is most important when running a motor at less than full speed.
- Since AC drives are used to provide slower running speeds, there must be a means of maintaining a constant magnetic flux in the motor. This method of magnetic flux control is called the volts-per-hertz ratio.
- With this method, the frequency and voltage must increase/decrease in the same proportion to maintain good torque production at the motor.




$$\text{Volts/Hertz} = \frac{460\text{V}}{60 \text{ Hz}} = 7.67$$



Pulse Width Modulation




VOLTAGE WAVEFORM AT MOTOR 500' LDS, 8.0kHz, 60Hz, IDLE, NO FILTER







DATE: 09/27/95

Control Signals




Typical Drive System

Input Power



Control



Drives are just one piece of the process

Application Considerations

Power- What kind of Power?

- An important point, to control the speed of a motor it must be a 3 Phase Motor!!!
- Typical VFDs on the low voltage side can control 208V, 230V, 380V, 460V, 575V motors!

Selecting AC Drives

- Size by Motor FLA.
- Voltage, HP and Load Type/Application
- It's also useful to know the motor base speed, service factor, enclosure type, insulation Class of the motor and Nema design.

MANUFACTURER									
PE-21 PLUS™					PREMIUM EFFICIENCY				
ORD. NO.	1LA02864SE41			MAG.	21.8				
TYPE	RGZESD I			FRAME	286T				
HP	30.00			SERVICE FACTOR	1.15			3 PH	
AMPS	77.5			VOLTS	230				
RPM	1765			HERTZ	60				
DUTY	CONT 40°C AMB.				DATE CODE				
CLASS INSL.	H	NEMA DESIGN	B	ENV. CODE	G	NEMA NOM. EFF.	93.6		
SH. END BRG.	50BC03JPP3			OPP. END BRG.	50BC03JPP3				
Inverter Duty AC Induction Motor <small>made in U.S.A.</small>									

What type of Enclosure?

- Brand Names

- Open Panel



- Sold when others mount in an enclosure
 - OEMs , system integrators, panel builders
 - Sold for wall mounted applications

- Enclosed



- Sold to customers needing a “ready to use” solution
 - Sold to customers who value a package designed and assembled by a major company




Altivar 61



- Type 1 solution for wall mounting

- Optional conduit kit
 - 460 Vac range
 - 1 to 450 HP
 - 208/230 Vac range
 - 1 to 75 HP
- Ability to order one part number
 - Add “T1” to the end of part number
 - Drive and conduit kit ship together
 - in one box
 - or strapped together


M-Flex VFD (1 to 500hp)




Seismic Qualification



- 1st Drive manufacturer to meet new standards
 - New Seismic Design Categories replace Seismic Zones
- Tested to ICC ES AC156
 - Uniform acceptance test protocol
 - Shaker table tested at Wylie Labs
 - Importance factor of 1.5
 - Operational after event
 - S_s (spectral response acceleration at one second period) > 2.67g



Reliability & Thermal Management



- Thermal modeling

- 50°C de-rating, high altitude, clogged filters simulations
- Air flow and direction optimization

- Design Verification

- Extreme tolerance verification
 - 40°C, 2% AC line voltage unbalance
 - 460 VAC \pm 10% under full load
 - Elevated input currents (low impedance system)
- Thermal couple measurements for verification

Long Lead Length – Stator Issues

- Special considerations


- Impedance mismatch between drive/cable and motor
- Carrier frequency / switching frequency
- Cable lead length
- dV/dT – Rise time of IGBT's
- Voltage spikes
- Reflected waveform can cause voltage doubling at the motor

Stator Failure

- The Result – Phase to Phase, Coil to Coil and Turn to Turn Failures

- Insulation Failure


- ✓ Highest voltage stress occurs between the turns in the first one or two coils in a phase group



VFD Design Considerations – Bearings

- **Special considerations:**

- Rectifiers switching 3 Output / Unbalanced
- Fluctuation of Motor V respect to Ground
- Common Mode Voltage a primary cause of Bearing Current
- Voltage build-up of 5-30VDC on the shaft is possible
- Typical flash point is bearings



VFD Design Considerations – Motors

● Bearing Solutions

- Decrease carrier frequency from drive
- Insulate bearings / Ground shaft with a brush
- Common mode filter
- Specify and purchase NEMA MG1, Part 31 Motors

● Stator Solutions

- Lower the carrier frequency of the drive
- Load reactor / Output filters
- Specify and purchase NEMA MG-1, Part 31 motors
 - Standard NEMA B motors with class F HPE insulation
 - 1.15 Service factor or Better
 - Output Filters where recommended

Consider specifying NEMA MG1, Part 31 motors

Power Factor Correction Capacitors

● Issues

- Install on line side of VFD
- Analyze to avoid harmonic frequency resonance conditions
- Random switching of PF correction capacitors may cause voltage transients on the AC line that could cause nuisance overvoltage control tripping.

● Solution

- Install a line reactor to reduce the magnitude of the line transients, thus preventing tripping
- Have PF correction capacitors tuned to avoid harmonic frequency resonance conditions

Questions



Contact info:

- Mike.Mattingly@us.schneider-electric.com
- 317-292-4537 cell

