

# EMC Mini Symposium - Audio Break Through



Ji Hoon Jang, Sandeep Chandra, Ketan Shringarpure  
EMC Team, Google Hardware  
Oct 03 2019

# Overview

- Basics of audio breakthrough (ABT) testing
- Calibration and process of testing
- Things that can go wrong (variations) in the lab ABT testing
- Explaining the variations
- Methods to do bench level ABT testing, enabling easy debugging

# Basics




# Audio Breakthrough (ABT) - Immunity Test

EMC Test Signal & Interference Calibration - Standard


Audio : 1 kHz




Carrier :  
80 MHz - 6 GHz



Total Signal (AM)




EMC  
Test  
Signal






# ABT test setup





# Audio Breakthrough (ABT) - Definition

ABT Uplink / Downlink



# Audio Breakthrough (ABT) - Standard

## Performance Criteria (Pass/Fail)



? How to measure reference level  
How to measure interference level

# Audio Breakthrough (ABT) - Standard

## Sound Pressure Level (dB SPL) vs dB Pa.

dB SPL is the level with the reference level 20  $\mu$ Pa


1 Pa is  $20 \log_{10} (1 \text{ Pa}/20 \mu\text{Pa}) = 94 \text{ dB SPL}$

dB Pa is the level with the reference level 1 Pa

1 Pa is  $20 \log_{10} (1 \text{ Pa}/1 \text{ Pa}) = 0 \text{ dB Pa}$

-35dB Pa = 60 dB SPL = Average conversation level

Sound source	dB SPL
Colt 45 pistol - 8 meters	140
Threshold of pain	130
Rock Concert	120
Night club music	110
Chainsaw / Jet ski	100
Lawnmower	90
Cabin of jet aircraft cruising	80
Car - 10 meters	70
Average conversation - 1 meter	60
Average suburban home (night)	50
Quiet auditorium	40
Quiet whisper - 1.5 meters	30
Extremely quiet recording studio	20
Anechoic Chamber	10
Threshold of hearing	0




# **Calibration Process and Standards**



# Audio Breakthrough (ABT) - Standard


## Interference Level Measurement (ETSI EN 301 489-52)




# Audio Breakthrough (ABT) - Standard

## Reference Level Measurement (ETSI EN 301 489-52)

### Downlink



### Uplink



# Audio Breakthrough (ABT) - Standard

## Acoustic Calibration (R&S TS9982 Application Note)


Sound Level Calibrator (B&K 4227)

Mouth Simulator (B&K 4227)


Pressure Microphone (B&K 4192)

Calibrate mic -> use that to calibrate  
sound pressure from mouth simulator

Step1  
: calibrate ref mic



Step2  
: calibrate mouth sim



$-5 \text{ dB Pa} = 0.56 \text{ Pa} \Rightarrow 0.5V \times 0.56 = 0.28 V$



# Audio Breakthrough (ABT) - Standard

## Acoustic Calibration (R&S TS9982 Application Note)

Sound Level Calibrator (B&K 4227)

Mouth Simulator (B&K 4227)

Pressure Microphone (B&K 4192)

Pressure Microphone



Sound Level Calibrator


Mouth Simulator



# Audio Breakthrough (ABT) - Standard

## Reference Level Measurement (R&S TS9982 Application Note)


Uplink



# Audio Breakthrough (ABT) - Standard

## Reference Level Measurement (R&S TS9982 Application Note)


Uplink



# Audio Breakthrough (ABT) - Standard

## Reference Level Measurement (R&S TS9982 Application Note)


Downlink



# Audio Breakthrough (ABT) - Standard


## Review of Reference Value in Standard (ETSI EN 301 489-52)

### Downlink




\*\* Downlink Reference Value = 99.913 dB $\mu$ V

### Uplink



\*\* Uplink Reference Value = 109.542 dB $\mu$ V

\*\* Values are from previous slides.



	Downlink Reference	Uplink Reference
Audio Level Meter @ 0 dB Pa = <b>1 Pa</b>	99.913 dB $\mu$ V / 1 Pa	109.542 dB $\mu$ V / 1 Pa
Audio Level Meter @ -35 dB Pa = <b>18 mPa</b>	64.913 dB $\mu$ V / 18 mPa	74.542 dB $\mu$ V / 18 mPa

# **Variations Observed and Explanations**



# Variations Observed in Third party labs


- Wrong calibration with sound level calibrator
- Wrong calibration procedure with mouth simulator and sound level calibrator
- Non-uniform field calibration and Field variations caused due to setup variations
- Placing audio pre-amp in a leaky (fields) shielded box inside the chamber.
- Sine-wave cancellation on mobile devices
- Second and third harmonics (sometimes higher than fundamental) ignored
- Frequency steps missing high Q resonances
- Variation due to phone orientation, different earphone lengths used by different labs and how they position the ear phones in the field

[Next](#)

# ABT - CMW500 Audio and Shield Box Test

The calibrator is controlled by closed loop in the speaker and reference microphone. If the calibrator is not sealed properly with the audio tube, it can increase the output pressure.


This is why a mouth simulator is used for calibration.






# Test - CMW500 - Downlink/Uplink

Downlink Measurement




Uplink Measurement





[Back](#)







# Test - Different Headphone



	Name	Length
1	Long White	118 cm
2	White	110 cm
3	Black	140 cm (Right) 120 cm (Left)
4	Yellow	140cm












# Test - Headphone Placement




[Back](#)

# Test - Horizontal




# Test - Horizontal - 6 V/m Field Strength

Downlink













Uplink






# Test - Vertical




# Test - Vertical - 6 V/m Field Strength







Downlink



Uplink



# Test - Headphone Placement





# Methods for Bench Level ABT



# ABT - EMC Lab Test

Goal : Minimize these variations to have consistent results

Method : Provide the guideline to the outside lab.

Procedures : By setting up Audio Breakthrough (ABT) test in lab, we can test how each variations will affect the measurement results

Debug ability : Ability to debug the failure while not working in active field

# Bulk Current Injection -ABT Test

No Full-size Chamber

No Field Calibration

No Interference Antenna


No Cable or antenna placement variation

Fast and can use more frequency points

Easy to Debug



R&S CMW500



# ABT - CMW500 Audio Generator / Analyzer

2 Inputs / 2 Outputs


Analog / Digital

Frequency Spectrum

Single / Multi Tone Measurement

Current/Average/Extreme


Sampling Frequency = 48 kHz




# ABT - R&S Z10 RF Shield Box

Frequency range up to 6 GHz


Shielding characteristics ( $< 80$  dB)



# Chamber ABT Test





Field calibration





Shield box with acoustic setup



Call box setup





# Comparison between Chamber ABT and BCI ABT




Red - Chamber ABT 6V/m  
Blue - BCI ABT -15dBm

# Comparison between Chamber ABT and BCI ABT







# BCI Placement



Center




Far from the phone



Close to the phone

# Comparison between Chamber ABT and BCI ABT




# Conclusions

- Variations are expected for ABT when tested in third party labs
- Setup and process should be carefully examined to ensure correct test process
- BCI ABT method takes out lot of variation. Gives ability to reproduce and debug on bench level without the need for full-size chamber.

# **Appendix - Audio Breakthrough (ABT)**





# Comparison between Chamber ABT and BCI ABT





power\_15\_close  
power\_15\_far  
power\_15\_wide

# Comparison between Chamber ABT and RCI ART





power\_18\_close  
power\_18\_far  
power\_18\_wide

# Comparison between Chamber ABT and BCI ABT



# Comparison between Chamber ABT and BCI ABT





# Audio Breakthrough (ABT) - Standard

## Handsfree Application

In ETSI EN 301 489-52,


When an external loudspeaker is used, the SPL from the external loudspeaker is higher than that from the earpiece of the portable by a certain amount in order overcome a high ambient noise level.

Two methods can be used to achieve the required SPL:

- **the downlink reference level shall be increased** by the same amount in order to compensate for the difference in SPL; or
- the distance between the loudspeaker and the measuring microphone shall be adjusted during the measurement procedure resulting in the required SPL.


# Audio Breakthrough (ABT) - Standard

Reference Level Measurement with earphone - Step 1



# Audio Breakthrough (ABT) - Standard

Reference Level Measurement with earphone - Step 2



# Audio Breakthrough (ABT) - Standard

## Reference Level Measurement with earphone (R&S TS9982 App Note)

Mobile Speaker Audio Level = 96.902 dBμV

Handsfree Speaker Audio Level = 98.890 dBμV

Difference between Mobile and Handsfree Speaker = 1.988 dB

Handsfree Downlink Reference Value

= Mobile Downlink Reference Value + Difference

= 111.53 dBμV

The screenshot shows the 'Audio Breakthrough Calibration' software window. It has several sections:

- Devices:** AF Generator (OMW500-GSM), AF Analyzer (OMW500-GSM), Communication Tester (OMW500-GSM), and a Switch Unit (Switch RSE) with a 'Switching...' button.
- Other Settings:** Mobile phone band for setting up a call (GSM 850), Unit for displaying results (dBμV), and Output voltage for Handsfree calibration (0.040 V).
- Measurements:** AF Generator Output (AF 1 OUT), Do Artificial Mouth Calibration (checked), AF Analyzer Input (AF 1 IN), Do Uplink Reference Measurement (checked), AF Analyzer Input (CODEC 1), Do Downlink Reference Measurement (checked), Use Artificial Mouth (selected), AF Analyzer Input (AF 2 IN), and Handsfree Set Calibration (checked) with AF Analyzer Input (AF 2 IN).
- EUT Information File for Storing the Measurement Results:** A text field containing 'ABT Test' is highlighted with a red box.
- Table:** A table with 6 columns: Calibration Parameter, Current, Previous, Delta, Unit, and Measurement Time. The table lists various calibration parameters and their values.
- Buttons:** 'Save Values', 'Start Audio Calibration', and 'Close'.

Calibration Parameter	Current	Previous	Delta	Unit	Measurement Time
Artificial Mouth: Acoustic Calibrator 0 dBPa	0.847	1.015	-0.168	V	07-11-2016 / 07:48:43
Artificial Mouth: Generator Level for -5 dBPa	2.530	0.546	1.984	V	07-11-2016 / 07:48:48
Uplink Reference Value	99.913	126.733	-26.820	dBμV	07-11-2016 / 07:48:52
Mobile Downlink Reference Value	109.542	117.884	-8.342	dBμV	07-11-2016 / 07:48:53
Mobile Speaker Audio Level	96.902	55.517	41.385	dBμV	07-11-2016 / 07:48:56
Handsfree Speaker Audio Level	98.890	-24.480	123.370	dBμV	07-11-2016 / 07:48:58
Difference between Mobile and Handsfree Speaker	1.988	0.910	1.078	dB	07-11-2016 / 07:48:58
Handsfree Downlink Reference Value	111.530	-9.180	120.710	dBμV	07-11-2016 / 07:48:58

# **Audio Breakthrough (ABT) - Standard**

**Field Calibration - Number of points, amplifier thermostability, metallic box under the table**

**Freq Step = 1%**

**Distortion to 2kHz, 3kHz, and so on.**

**Acoustic Calibration**

**Mic Sensitivity, Different calibration steps, headphone positioning with artificial mouth**

**Audio Measurement/Susceptibility of Audio Box**

**Position Phone/Cables**

**Echo Cancellation - Max Hold, Turn on/off between Freq Steps, Clear the data measure it again, Dwell Time**

# ABT - B&K Microphone

4231  
Acoustic  
Calibrator  
1kHz – 94/114dB

1704-A-001  
200V mic power supply  
Built-in battery or 110V

AO-0414-030  
cable




AO-0426-D-005  
BNC to BNC cable



Voltage signal  
to oscilloscope/  
Analyzer

4192 Mic quick specs:  
Sensitivity: ~~12.5mV/Pa~~ → 13.6mV/Pa  
Frequency Range: 3.15-20kHz  
Dynamic Range: 19-162 dB  
Operation temperature: -30 to 300deg C  
Polarization: 200V

Preamp = x10 gain  
Measurement Results = 392mV ptp  
Sensitivity : 13.6mVRMS/Pa =  
19.23mVpeak/Pa  
Expected Results = 385mV ptp



# Mouth Simulator/Acoustic Tube/Microphone Test



# ABT - CMW500 Remote Control Comm

Serial Communication of Single Tone Measurement Using **Matlab/Python** and **USB port**

## Code

```
55 # Start the audio measurement.
56 # Query the average and extreme measurement results from the result table.
57 ↘
58 cmw.write('FETCh:AUdio:MEAS:ANALog:SINGletone:Average?');
59 current_temp = cmw.read()
60 current = current_temp.strip().split(',');
61
62 print('READ VALUE')
63
64 print "Reliability:", current[0]
65 print("THD Percent[%]: {:.5f}" .format(float(current[1])))
66 print("THD dB: {:.5}" .format(float(current[2])))
67 print("THD + N: {:.5}" .format(float(current[3])))
68 print("SINAD: {:.5}" .format(float(current[4])))
69 print("SNR: {:.5}" .format(float(current[5])))
70 print("DC Level: {:.5}" .format(float(current[6])))
71 print("Frequency: {:.5}" .format(float(current[7])))
72 print("Weight Level RMS: {:.5}" .format(float(current[8])))
73 print("Band Level RMS: {:.5}" .format(float(current[9])))
74 print("Weight Level Peak: {:.5}" .format(float(current[10])))
75 print("Band Level Peak: {:.5}" .format(float(current[11])))
76
77 cmw.write('FETCh:AUdio:MEAS:ANALog:STATe?');
78
79 state = cmw.read()
80 print('State:', state)
```

## Output

```
[jhjiang-macbookpro:python_cmw500 jhjiang$ python cmw_audio_v0
('Connected to:', u'Rohde&Schwarz,CMW,1201.0002k50/164807,3.7.10\n')
('Count :', u'5\n')
('Dfreq :', u'1000\n')
('Generator:', u'ON\n')
READ VALUE
Reliability: 0
THD Percent[%]: 0.03
THD dB: -84.135
THD + N: 0.536
SINAD: 75.908
SNR: 77.533
DC Level: 0.00012449
Frequency: 1012.9
Weight Level RMS: 0.99786
Band Level RMS: 0.99818
Weight Level Peak: 1.4234
Band Level Peak: 1.4094
('State:', u'RUN\n')
```



# CMW500 - Uplink/Downlink

Setup Uplink and Downlink successfully

GSM - FRV1 - speech instead of echo

Select Audio Measurement - Microphone and Speaker Test

Uplink - Digital Measurement [Unit - Full Scale]

Downlink - Analog Measurement [Unit - V]

Next Step - Audio Calibration with the setup, remove the earphone and do the better sealings (Max : -15), R&S how to set the spectrum (data points)







Figure 3-3: Test setup for microphone and speaker test

# Third party Labs

Some labs use CMW200 and separate codec cable for speech analysis.


They use artificial mouth for downlink calibration, but not the calibrator.

They use artificial mouth for uplink calibration (Many variations between the phone).




# 3 V/m Field Strength

Downlink




Uplink




# 6 V/m Field Strength

Downlink




Uplink




# 10 V/m Field Strength

## Downlink




## Uplink




# 3 V/m Field Strength

Downlink




Uplink




# 6 V/m Field Strength

Downlink




Uplink




# 10 V/m Field Strength

## Downlink




## Uplink






# Vertical Comparison

Downlink




Uplink




# 6 V/m Field Strength


Downlink




Uplink





# Comparison between Chamber ABT and RCI ART



# Comparison between Chamber ABT and BCI ABT




# Comparison between Chamber ABT and RCI ART




black\_ear\_loose\_6V\_GSM  
black\_ear\_loose\_power\_18\_wi


# Comparison between Chamber ABT and BCI ABT



# Comparison between Chamber ABT and BCI ABT




# Comparison between Chamber ABT and BCI ABT







# Comparison between Chamber ABT and BCI ABT



# Comparison between Chamber ABT and BCI ABT



# Comparison between Chamber ABT and BCI ABT



# Comparison between Chamber ABT and RCI ART

