

Circuit Breakers Presentation
IEEE/PES Pittsburgh, PA
11/11/99

A. Wilson/Doble Engineering Company




Diagnostics For Substation Apparatus

- ▶ Circuit Breakers
- ▶ Transformers
- ▶ Bushings


Diagnostics NOT Data

Power Factor Rate of Change



Multiple Locations-One Remote Server

One Substation-One Local Server



CIGRE Failure Analysis Study

- ▶ **Control Circuits**

 - Major Failures - 30%**

 - Minor Failures - 20%**

- ▶ **Main Contacts**

 - Major Failures - 15%**

 - Minor Failures - 10%**

- ▶ **Motion**

 - Major Failures - 12%**

 - Minor Failures - 6%**

- ▶ **Ancillary Equipment**

 - Major Failures - 31%**

 - Minor Failures - 28%**

Circuit Breaker Measurements

- ▶ **Control Circuits**

- 52-A and 52-B Auxiliary Contact Status**
 - Trip and Close Coil Currents**

- ▶ **Main Contacts**

- Trip and Close Coil Currents**
 - Phase Currents A,B, and C**

- ▶ **Insulation**

- Bushings - PF and Capacitance**

- ▶ **Motion**

- Breaker Mechanism-Total-Travel, Over-Travel, Rebound, and Velocity**

- ▶ **Ancillary Equipment**

- Motor Current**

- Pressure - SF6, Air Tank, or Hydraulic**

- Heater Status**

- Temperature - Ambient, SF6 Tank, or Cabinet**




Identified Problems/Failures

- ▶ **Control Circuits (2)**
 - Fails to Trip on Command**
 - Fails to Close on Command**
 - Control Circuit Performance**
- ▶ **Main Contacts**
 - Current Interruption/Initial Performance**
 - Contact Erosion**
 - Re-strike**
- ▶ **Insulation (3)**
 - Deteriorated Insulation**
 - Change in PF/Capacitance**
- ▶ **Motion (2)**
 - Mechanism Performance - Lubrication, Damping, and Binding**
- ▶ **Ancillary Equipment (15)**
 - Performance - Stored Energy, Pressure, Motor and Heaters**




Contact Malfunction

- ▶ Breaker Type: Air-Blast Multi-Interrupter Breaker
- ▶ Four of the interrupting contacts along with the isolating contacts did not operate initially




Contact Malfunction

- ▶ Total Trip Coil Time for each phase.
- ▶ 130+ operations in a 3 year period.
- ▶ The spike indicates the pole disagreement on Phase B.




Contact Malfunction

- The trace of Phase B indicates re-ignition of current




Interrupting Time of the Main Contacts

- ▶ Varies slightly with load current.
- ▶ Repeatable.
- ▶ The interrupting time did not indicate pole disagreement




Motion


Future analysis may have to incorporate seasonal adjustments



SF6 Pressure (Hourly)



Motor Recording Belt Slipping



INSITE Diagnostics

- ▶ **Linked To:**
Failure Statistics
Reliability
Maintenance
- ▶ **Using:**
Statistics within Context of Limits
Compensation for Operating Conditions
- ▶ **To Give:**
Conditioned Based Maintenance

Conclusion

- ▶ Breakers have extremely repeatable functionality.
- ▶ INSITE sensors are robust and sensitive enough.
- ▶ Diagnostics must be focused