

Factory and Field Verification Tests of Controlled Switching System (CSS)

according to CIGRE WG13.07

**H. Ito, H. Kohyama, K. Kamei, T. Yonezawa
TM T&D Corporation, Japan**

**H. Wilson, S. Billings
Mitsubishi Electric Power Products, Inc. USA**

Factory and Field Verification Tests of CSS

Outlines

1. CIGRE Testing Requirements
2. Individual Component Testing
3. Integrated System Testing
4. Field Verification
5. Conclusions

1. CIGRE WG13.07 Documents for Testing

- ❑ CIGRE proposed the testing requirements and their procedures for CSS.**
- ❑ The guide emphasizes importance of compensation for operating time variations.**
- ❑ Some mechanisms showed a significant delay after idle times of breakers for only a few hours.**
- ❑ The method of determining the optimum close target is proposed by pre-strike characteristic.**

2. Individual Component Testing

145kV independent-operated GCB with spring mechanisms



Controller



Factory Tests for Circuit Breakers

Electrical performance tests

- ☐ Dielectric characteristics (RDDS / RRDS) ❖
- ☐ Minimum arcing time for reignition-free window ❖


Mechanical performance tests

- ☐ Variations of operating time on operating conditions ❖
- ☐ Delay of operating time after an “idle time” ❖


RDDS: Rate of Decrease of Dielectric Strength

RRDS: Rate of Rise of Dielectric Strength


Pre-strike voltage for a cycle of power frequency




RDDS measured by pre-strike test



Dielectric recovery characteristic of 550kV 1-break GCB




Conditional Compensation




Deviation from average closing time plotted as functions of temperature and control voltage

Idle Time Compensation



Idle time dependence of circuit breaker with a conventional hydraulic operating mechanism

Idle Time Compensation



Idle time dependence of circuit breaker with the spring operating mechanisms

3. Integrated System Testing

245kV independent-operated GCB with spring mechanisms




Factory Tests for Integrated System

Complete performance tests


- ☐ Compatibility of circuit breaker, controller & sensor ❖
- ☐ Age related “drift” of operating time ❖
- ☐ Distribution of switching instant ❖
- ☐ Maximum making voltage for voltage zero target ❖
- ☐ Verification of reignition-free ❖

Drift of the closing time measured with and without adaptive control



Without Adaptive Control



With Adaptive Control




Controlled Switching Tests for voltage zero




**Distribution of making voltages and closing instants
using 145kV and 362kV GCB**

Commissioning Tests at Site




Commissioning tests of 145kV spring operated GCB

Waveforms of 2nd making test





(a) Voltage waveform of 2nd making test





(b) Current waveform of 2nd making test


Waveforms of 3rd making test




Waveforms of 6th making test



Waveforms of 10th making test



(a) Voltage waveform




(b) Current waveform

4. Field Verification Test





Commissioning tests of 204kV hydraulic operated GIS




Controlled shunt reactor de-energization and energization



Operating records of temperature, hydraulic pressure, closing and opening times over one year



Idle time characteristic of 204kV GIS with hydraulic drives



Summary of Results

- ☐ Effective compensation for deviations of operating time associated with past operations has been demonstrated.
- ☐ The requirement of idle time compensation can be judged from the measurement up to 100 hours.
- ☐ Innovative operating mechanisms do not show any delay of the operating times for idle time up to 1000 hours.
- ☐ Controlled shunt capacitor switching in the field showed more successful results due to the adaptive control.
- ☐ Commissioning test demonstrates successful reactor opening without any reignition.

5. Conclusions

- ☐ CIGRE WG13.07 recommendation successfully covers all the testing requirements and their procedures.
- ☐ CSS verified according to the CIGRE recommendation demonstrates successful results in the field.

Thank you very much for your attention